



ADDENDUM #2
FORMAL BID 2010-147
KITSAP COUNTY COURTHOUSE
COURTROOM INTERIOR IMPROVEMENTS

TO: All Respondents

FROM: R'Lene J. Orr, Purchasing Manager

CLOSING DATE: Tuesday, September 21, 2010 (*CHANGED IN ADDENDUM #1*)

BID NO.: 2010- 147 FB Kitsap County Courthouse
Courtroom Interior Improvements

DATE: September 15, 2010

Please note the change to the above referenced Formal Bid.

The following shall be incorporated through Addendum to the 8-26-2010 Bid Documents for Kitsap County Formal Bid 2010-147, Kitsap County Courthouse Courtroom Interior Improvements Project:

01600 – PRODUCT REQUIREMENTS

SUBSTITUTION REQUESTS:

Section 15869, Paragraph: 2.1

Specified Items: Roof Mounted Exhaust Fans
Approved Substitution: ILF CRDA
Submitted By: Air Tec Company

Section 16500, Paragraph: All

Specified Items: Lighting Fixtures and Occupancy Sensors
Approved Substitution: "Day-O-Lite" fixtures for RF1, RF2 & RF4.
"Sensor Switch" for occupancy sensors OSC, OSW,
OWS & PP.
Submitted By: iR, illuminating Resource, LLC

Section 16500, Paragraph: All

Specified Items: Lighting Fixtures
Approved Substitution: "Omega" fixture for RF3.
"mcPhilben" for exit fixture EX1
Submitted By: Sea-Tac Lighting & Controls, LLC

08200 – FLUSH WOOD DOORS

PART 2 PRODUCTS

2.2 DOOR CONSTRUCTION, GENERAL, **Change:**

- A. Door Face Material for Factory Finish:
 - 4. Match: Slip match.

08700 – DOOR HARDWARE

PART 3 EXECUTION

3.5 HARDWARE SCHEDULE, **Replace with the following:**

HARDWARE SETS

Finish on all hardware: US26D/626, basis of design: Corbin/Ruswin.

Utilizing the devices and equipment listed below, the final hardware selection will be made in consultation with Hardware Supplier, Owner & Architect.

HW1

DOORS: TYPE 'C'; Courtrooms 271, 272 & Hearing Room 274 (east wall) (**added door**) (3 doors total)

- 3 ea Butts BB179 US26D 4 1/2 x 4 1/2
- 1 ea Exit device ED5200A 630 W036 M54
- 1 ea Exit device trim L955 630
- 1 ea Rim Cylinder Housing 3070-178 x 626
- 1 ea Interchangeable core 8000 XX x 626
- 1 ea Door closer DC6210 689 M54
- 1 ea Kick plate K1050 10 x 34 630
- 1 ea Wall stop 403 x 626
- 1 ea Gasket S44D x 17'

HW2

DOORS: TYPE 'B': Jury Deliberation 273A & 273B, Hearing Room 274 (west wall) (3 doors total).

- 3 ea Butts BB179 US26D 4 1/2 x 4 1/2
- 1 ea Lockset ML2051 LWA 630 SA114 M17 LC
- 1 ea Cylinder housing 1070-114-A01 626
- 1 ea Interchangeable core 8000 XX x 626
- 1 ea Door closer DC6210 689 M54
- 1 ea Wall stop 403 x 626
- 1 ea Gasket S44D x 17'

HW3

DOORS: TYPE 'A': Hallway Access Doors
(2 doors total).

- 3 ea Butts BB179 US26D 4 1/2 x 4 1/2
- 1 ea Lockset ML2051 LWA 630 SA114 M17 LC
- 1 ea Cylinder housing 1070-114-A01 626
- 1 ea Interchangeable core 8000 XX x 626
- 1 ea Door closer DC6210 689 M54
- 1 ea Wall stop 403 x 626
- 3 ea Silencers 4279-014-B06 Grey

HW4

DOORS: TYPE 'B': Toilet Room Doors
(4 doors total).

- 3 ea Butts BB179 US26D 4 1/2 x 4 1/2
- 1 ea Privacy ML2030 LWA 630 SA114 M17
- 1 ea Door closer DC6210 689 M54
- 1 ea Wall stop 403 x 626
- 3 ea Silencers 4279-014-B06 Grey

10426 – SIGNAGE AND GRAPHICS

PART 2 PRODUCTS

2.04 SIGN SCHEDULE, **Add:**

B. Additional signs required:

1. In 1" high letters: "OCCUPANT LOAD = 104" (mount above south exit door inside Courtroom 271).
2. In 1" high letters: "OCCUPANT LOAD = 94" (mount above south exit door inside Courtroom 272).
3. In 1" high letters: "DOOR TO REMAIN UNLOCKED WHEN ROOM IS OCCUPIED" (mount on strike side of door inside south exit door in Courtrooms 271 & 272).

DRAWINGS

SHEET A2.2

DOOR SCHEDULE

Add to Door Schedule: Door Type 'C': 3'x7', solid core, red oak veneer, 20 minute rated with 6" top, middle & side rails, 12" bottom rail, 24"w x 36"h top glass and 24"w x

24”h bottom glass. For glazing in wood doors, see specification division 08200, section 2.5.

SHEET A2.2
1/A2.2 SECOND FLOOR PLAN

Change Door Type Mark: For Courtrooms 271 & 272, change Door Type Mark from Type ‘A’ to Type ‘C’.

Add New Door & Hollow Metal Frame: Door in east wall of Hearing Room 274 is currently labeled “existing to remain”. Change this to provide a new Type ‘C’ door in a new hollow metal frame.

SHEET E1.1
1/E1.1 SECOND FLOOR LIGHTING PLAN

Add Light Fixture: Add one additional RF1 type light fixture in the entry lobby on the south side of Courtrooms 271 & 272 (refer to A2.4 Reflected Ceiling Plan for correct layout).

SHEET M1.0
ELECTRIC TANKLESS WATER HEATER SCHEDULE

Omit last sentence in Footnote #3: Omit the last sentence in Footnote #3 that states: “MC to provide a motor rated relay for controls”.

END ADDENDUM NO. 2