



ADDENDUM #3

INFORMAL BID 2018-126 CENTRAL KITSAP TREATMENT PLANT PROCESS BUILDING HVAC REPLACEMENT

TO: All Respondents
FROM: Colby Wattling
CLOSING DATE: April 24, 2018 at 3:00 PM (UNCHANGED)
REF NO.: 2018-126 IFB
DATE: April 19, 2018

The purpose of this addendum is to modify the Contract Documents for the referenced project. This addendum shall become a part of these Contract Documents. Bidder shall acknowledge receipt of this 1 page addendum (including attachments) on the Bid Form.

INVITATION TO BID

Item 1. REPLACE the second paragraph with the following:

Provide all labor, equipment & materials to remove and replace two existing 6-Ton Trane Roof Top heating and cooling air handler units.

New units shall be Carrier, Trane, or approved equal.

End Addendum #3