



ADDENDUM #1

INFORMAL BID
2019-111

SKRP Maintenance Building

TO: All Respondents
FROM: Colby Watling
CLOSING DATE: March 6, 2019 at 3:00 PM (UNCHANGED)
REF NO.: 2019-111 IFB
DATE: February 28, 2019

The below are **questions** and **answers** which occurred during the site visit that took place Wednesday, February 27, 2019.

1. What is being requested for the gauge of the metal siding?
The gauge will be 24 gauge with exposed fasteners. With 3' wide panels.
2. Will any trees be removed?
No.
3. What to do with the (2) stumps in the footprint of the shop?
Contractor may dispose of them elsewhere in the park.
4. Will there be any restrooms?
No.
5. Will there be any water?
No.
6. What type of roll top door?
Sectional door, no chain fall.
7. What specifics towards fill material to be brought in?
Clean fill material. Area to be leveled to existing grade of site.
8. What type of construction fencing is required to keep the site/construction area secure during construction? Orange construction fencing or chain-link fence panels?
Chain-link fence panels.

There are no other changes to the original specifications other than what is changed by Addendum. Acknowledgement of receipt of this and all ADDENDUM is required.

END OF ADDENDUM # 1